

Typical Specifications

Model: TR

Description: Unit shall be a tiered spun aluminum, roof mounted gravity ventilator.

Certifications: Fan shall be manufactured at an ISO 9001 certified facility.

Construction: The unit shall be of bolted and welded construction utilizing corrosion resistant fasteners. The spun aluminum structural components shall be constructed of minimum 16 gauge marine alloy aluminum, bolted to a rigid aluminum support structure. The aluminum base shall have continuously welded curb cap corners for maximum leak protection. The spun aluminum baffle shall have a rolled bead for added strength. Birdscreen constructed of 1/2" mesh shall be mounted across the air opening. Unit shall bear an engraved aluminum nameplate. Nameplate shall indicate design CFM and static pressure. Unit shall be shipped in ISTA certified transit tested packaging.

Product: Unit shall be model TR as manufactured by Loren Cook Company of Springfield, Missouri.

10/20/03