



**COOK**

# Wall Collar

DATE: \_\_\_\_\_

PROJECT: \_\_\_\_\_

LOCATION: \_\_\_\_\_

SWD, AWB, AWD, EWB  
 EWD, XWD, XWHD XLW  
 XMW, XLWH, XMWH  
 Propeller Wall Fans

**DIMENSION DATA**

SWD,XWD,XWHD AWD,AWB,XLW XMW,XLWH,XMWH Size	EWD EWB Size	A Sq.	B Sq.	C Sq.	D	Wall Opening	Galvanized Steel Gauge	Optional Aluminum Thickness
8	-	12-3/16	15-1/2	10-3/8	12	13-1/4	18	.080
10	-	16-3/16	19-1/2	14-3/8	14-5/16	17-1/4	18	.080
12	-	16-3/16	19-1/2	14-3/8	14-5/16	17-1/4	18	.080
14	-	20-3/16	23-1/2	18-3/8	15-5/16	21-1/4	18	.080
16	-	20-3/16	23-1/2	18-3/8	15-5/16	21-1/4	18	.080
18	-	24-1/4	27-1/2	22-3/8	17-1/2	25-1/4	18	.080
20	-	24-1/4	27-1/2	22-3/8	17-1/2	25-1/4	18	.080
24	-	30-1/4	33-9/16	28-7/16	18-11/16	31-5/16	18	.080
30	24	36-1/4	39-9/16	34-7/16	18-11/16	37-5/16	18	.080
36	30	42-1/4	45-9/16	40-1/2	19-7/16	43-5/16	18	.080
42	36	48-1/4	51-5/8	46-1/2	19-7/16	49-3/8	16	.080
48	42	54-1/4	57-5/8	52-1/2	19-11/16	55-3/8	16	.100
54	48	60-1/4	63-11/16	58-9/16	19-11/16	61-7/16	14	.100
60	54	66-1/4	69-11/16	64-9/16	19-11/16	67-7/16	14	.100
-	60	72-1/4	75-11/16	70-9/16	19-11/16	73-7/16	14	.100
-	72	84-1/4	87-11/16	82-9/16	19-11/16	85-7/16	14	.100

ALL DIMENSIONS IN INCHES.

FASTENERS SHOULD BE PLACED ON 6" TO 10" CENTERS ON THE PERIMETER OF THE WALL COLLAR. WALL COLLAR SHOULD BE CAULKED TO THE EXTERIOR OF THE WALL. FAN NOT INCLUDED.

